

## Bureau Veritas Consumer Products Services Germany GmbH

Businesspark A96 86842 Türkheim Germany + 49 (0) 40 740 41 - 0 cps-tuerkheim@de.bureauveritas.com

## **Certificate of compliance**

**Applicant:** 

Delta Energy Systems GmbH

Tscheulinstrasse 21 79331 Teningen

Germany

**Product:** 

Automatic disconnection device between a generator

and the public low-voltage grid

Model:

SOLIVIA 11EUG4TR EOE48030114

## Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with DIN V VDE V 0126-1-1:2006-02 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function which the distribution network provider can access at any time.

## **Applied rules and standards:**

DIN V VDE V 0126-1-1 (VDE V 0126-1-1):2006-02 and "Generator at the public low-voltage grid, 4th edition 2001, guideline for connection and parallel operation of generators in the public low-voltage grid" with VDN additions (2005) from the German Electricity Association (VDEW) and Association of network operator (VDN).

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number:

11TH0120-VDE0126

Certificate number:

U12-0105

Date of issue:

2012-01-24

Valid until:

2015-01-23

Achim Häncher