

Certificate of Compliance

Applicant: Delta Energy Systems Germany GmbH
Tscheulinstraße 21
79331 Teningen
Germany

Product: Micro-generator in parallel with public low-voltage distribution networks

Model: SOLIVIA10EUT4TL EOE47030457

Intended use:

Automatic disconnection device with three-phase mains surveillance for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

EN 50438:2007 with default interface protection settings for Poland.

Basic limits:

over voltage 264,5V

under voltage 195,5V

over frequency 51,0Hz

under frequency 47,0Hz

anti-islanding protection 0,5s


The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 12KFS075-06

Certificate No: 12-042-00

Date of issue: 2013-03-05

Valid until: 2016-03-05



Horst Haug
Certification Department

