

# Certificate of Compliance

**Applicant:** Delta Energy Systems Germany GmbH  
Tscheulinstraße 21  
79331 Teningen  
Germany

**Product:** Micro-generator in parallel with public low-voltage  
distribution networks

**Model:** SOLIVIA30EUT4TL EOE48030458  
SOLIVIA20EUG4TL EOE48010364  
SOLIVIA15EUG4TL EOE48010362

## Intended use:

Automatic disconnection device with three-phase mains surveillance for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

## Applied standards and guidelines:

EN 50438:2007 with default interface protection settings.

*Basic limits:*

*over voltage 264,5V  
under voltage 195,5V  
over frequency 51,0Hz  
under frequency 47,0Hz  
anti-islanding protection 0,5s*


The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

**Report No:** 11KFS109-10

**Certificate No:** 13-133-00

**Date of issue:** 2013-08-22

**Valid until:** 2016-04-04



Horst Haug  
Certification Department

