

## Bureau Veritas Consumer Products Services Germany GmbH

Businesspark A96 86842 Türkheim Germany + 49 (0) 4074041-0 cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH Accredited according to EN 45011 -ISO / IEC Guide 65

## **Certificate of conformity NS protection**

Manufacturer / applicant: Delta Electronics, Inc.

39, Sec. 2, Huangdong Road Shanhua Dist., Tainan City 74144

TAIWAN, R.O.C.

Type of grid and plant protection:	Integrated NS protection
Assigned to generation unit type:	RPI H3A_12X RPI H3A_02X RPI H4A_12X RPI H4A_02X RPI H5A_12X RPI H5A_12X RPI H5A_02X (X=0~9,A~Z or blank; This is for marketing purpose.)

Firmware version: DSP: V0200 / RED: 0200 / COMM: 0200

Connection rule: VDE-AR-N 4105:2011-08 – Power generation systems connected to the

low-voltage distribution network

Technical minimum requirements for the connection to and parallel operation

with low-voltage distribution networks.

Applicable standards /

directives:

DIN VDE V 0124-100 (VDE V 0124-100): 2012-07 - Grid integration of

power generation systems - low voltage

Test requirements for power generation units to be connected and operated

parallel with the low-voltage distribution networks

The above mentioned grid and plant protection has been tested and certified according to the test guideline VDE 0124-100. The electrical properties required in the connection rule are satisfied.

- Setting values and disconnect times
- · Properly functioning functional chain "NS protection interface switch"
- · Technical requirements of the switching device
- · Active detection of stand-alone power systems
- Single-fault tolerance

## The certificate contains the following information:

- Technical specifications of the NS protection and corresponding power generation types
- Setting values of the protection functions
- Trip values of the protection functions

BV project number: 13TH0320 Certificate number: U14-0347 Date of issue: 2014-07-01

**Certification body** 

Dieter Zitzmann

(A partial representation of the certificate requires the written permission of BV CPS GmbH)

DAKKS

Deutsche
Akkreditierungsstelle
D-ZE-12024-01-01

SOCIAL ACCOUNTABILITY



## Annex to the NS protection Certificate of Conformity No. U14-0347

F.4 Requirements for the test report for the NS protection					
Extract from test report for NS protec "Determination of electrical propertie	Nr. 13TH0320				
NS protection as integra	ted NS protec	tion			
Manufacturer / applicant:	39, Sec. 2, Huango	Delta Electronics, Inc. 39, Sec. 2, Huangdong Road Shanhua Dist., Tainan City 74144 TAIWAN, R.O.C.			
Type of grid and plant protection:	Integrated NS pro	Integrated NS protection			
Assigned to generation unit type:	RPI H3A_12X RPI H3A_02X RPI H4A_12X RPI H4A_02X RPI H5A_12X RPI H5A_12X RPI H5A_02X (X=0~9,A~Z or blank; This is for marketing purpose.)				
Firmware version:	DSP: V0200 / RED: 0200 / COMM: 0200				
Integrated interface switch:	Type of switching equipment 1: Song Chuan 841-P-2A-F-C-H with 30ms Type of switching equipment 2: Song Chuan 841-P-2A-F-C-H with 30ms				
Measurement period:	2013-02-27 to 2013-07-24				
Protection function	Setting value	Trip value	Disconnection time <sup>a</sup>		
Voltage drop protection U <	184 V	184,0 V	160 ms		
Rise-in-voltage protection U>	253 V	253 V	499 s <sup>b</sup>		
Rise-in-voltage protection U>>	264,5 V	264,5 V	165 ms		
Frequency decrease protection f<	47,5 Hz	47,50 Hz	125 ms		
Frequency increase protection f>	51,5 Hz	51,50 Hz	156 ms		

<sup>&</sup>lt;sup>a</sup> proper time of interface switch 30 ms

The disconnect time (sum of trip time of grid and plant protection and delay time of interface switch) must not exceed 200 ms.

A check of the overall functional chain "NS protection – interface switch" resulted in a successful disconnection.

The above mentioned grid and plant protection with the assigned power generation units has met the requirements for islanding detection with the help of the active method (resonant circuit test).

The above mentioned NS protection meets the requirements for synchronization.

<sup>&</sup>lt;sup>b</sup> longest disconnection of the rise-in-voltage protection as a moving 10-minute-average, tested according clause 5.4.5.3.3 measurement a) of VDE 0124-100