

## Bureau Veritas Consumer Products Services Germany GmbH

Businesspark A96 86842 Türkheim Germany + 49 (0) 4074041-0 cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH Accredited according to EN 45011 -ISO / IEC Guide 65

## **Certificate of conformity NS protection**

Manufacturer / applicant:

Delta Energy Systems (Germany) GmbH

Tscheulinstraße 21 79331 Teningen Germany

Type of grid and plant protection:	integrated NS protection	
Assigned to generation unit type:	Solivia2.5EUG4TR EOE45010288, Solivia3.0EUG4TR EOE46010287, Solivia3.3EUG4TR EOE46010252, Solivia3.6EUG4TR EOE46010316	

Firmware version

SYS: 1.2.x

DC: 0.35.x; AC: 0.35.x; ENS: 0.35.x

**Connection rule:** 

VDE-AR-N 4105:2011-08 - Power generation systems connected to the

low-voltage distribution network

Technical minimum requirements for the connection to and parallel

operation with low-voltage distribution networks.

Applicable standards /

directives:

E DIN V VDE V 0124-100 (VDE V 0124-100):((2011-11)) - Grid integration

of power generation systems - low voltage

Test requirements for power generation units to be connected and operated

parallel with the low-voltage distribution networks

The above mentioned grid and plant protection has been tested and certified according to the test guideline VDE 0124-100. The electrical properties required in the connection rule are satisfied.

- · Setting values and disconnect times
- Properly functioning functional chain "NS protection interface switch"
- Technical requirements of the switching device
- Active detection of stand-alone power systems
- Single-fault tolerance

## The certificate contains the following information:

- Technical specifications of the NS protection and corresponding power generation types
- Setting values of the protection functions
- Trip values of the protection functions

BV project number:

11TH0316

Certificate number:

U12-0485

Date of issue:

2012-05-30

Valid until:

2015-05-29

**Certification body** 

Dieter Zitzmann

(A partial representation of the certificate requires the written permission of BV CPS GmbH)



D-ZE-12024-01-01



Manufacturer / applicant:	Delta Energy Systems (Germany) GmbH			
	Tscheulinstraße 21			
	79331 Teningen			
	Germany			
Type of grid and plant protection:	integrated NS protection			
Assigned to generation unit type:	Solivia2.5EUG4TR EOE45010288, Solivia3.0EUG4TR EOE46010287, Solivia3.3EUG4TR EOE46010252, Solivia3.6EUG4TR EOE46010316			
Firmware version:	SYS: 1.2.x			
	DC: 0.35.x; AC: 0.35.x; ENS: 0.35.x			
Integrated interface switch	Type of switching equipment 1: Transformer			
	Type of switching equipment 2: Relay			
Measurement period:	2011-12-16 - 2012-05-03			
Protection function	Setting value	Trip value	Disconnection time	
Voltage drop protection U <	184 V	184,8 V	199 ms	
Rise-in-voltage protection U>	257,6 V		516 s <sup>a</sup>	
Rise-in-voltage protection U>>	264 V	263,9 V	200 ms	
Frequency decrease protection f<	47,5 Hz	47,5 Hz	194 ms	
Frequency increase protection f>	51,5 Hz	51,5 Hz	194 ms	

<sup>&</sup>lt;sup>a</sup> longest disconnection of the rise-in-voltage protection as a moving 10-minute-average

The disconnect time (sum of trip time of grid and plant protection and delay time of interface switch) must not exceed 200 ms.

A check of the overall functional chain "NS protection – interface switch" resulted in a successful disconnection. The above mentioned grid and plant protection with the assigned power generation units has met the requirements for islanding detection with the help of the active method (resonant circuit test) and also fulfils the requirements for synchronisation to the grind.