



**BUREAU
VERITAS**

Certificate of compliance

Applicant: **Delta Electronics, Inc.**
39, Sec.2, Huandong Road
Shanhua Dist., Tainan City 74144
Taiwan

Product: **Grid-tied photovoltaic (PV) inverter**

Model: **RPI H5A_12X**
RPI H5A_02X

Note: "X" in the inverter name can be 0~9, A~Z or blank

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with Engineering Recommendation G59/3 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with isolating function that can access the distribution network provider at any time.

Applied rules and standards:

Engineering Recommendation G59/3:2013

Recommendation for the Connection of Generating Plant to the Distribution Systems of licensed Distribution Network Operators.

DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

The RPI H5A_12X and RPI H5A_02X are rated >16A per phase and ≤ 17kW (1 phase). The default values for "Small Power Stations" on the low-voltage grid were verified.

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: **PVUK140529C19-G59/3**

Certificate number: **U14-0536**

Date of issue: **2014-10-15**

Certification body

Dieter Zitzmann



Deutsche
Akkreditierungsstelle
D-ZE-12024-01-01

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to EN 45011 - ISO / IEC Guide 65

Appendix 13.1 Type Testing a Generating Unit

Extract from test report according the Engineering Recommendation G59/3

Nr. PVUK140529C19

Type Approval and declaration of compliance with the requirements of Engineering Recommendation G59/3.

Manufacturer / applicant:	Delta Electronics, Inc. 39, Sec.2, Huandong Road Shanhua Dist., Tainan City 74144 Taiwan	
Generating Unit technology	Grid-tied photovoltaic inverter	
Rated values	RPI H5A_12X	RPI H5A_02X
Maximum rated capacity	5,0 kW	5,0 kW
Rated voltage	230V	230V
Firmware version	Comm: V2.03, DSP: V2.01, RED: V2.00	

Note: "X" in the inverter name can be 0~9, A~Z or blank

Measurement period: 2014-08-08 to 2014-10-08

Description of the structure of the power generation unit (Figure 1):

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.




Figure 1 – Schematic structure of the power generation unit

Differences between Generating Units:

Difference between Model RPI H5A_12X and model RPI H5A_02X is a DC-switch, which is included in model RPI H5A_12X and not in model RPI H5A_02X.

The above stated Generating Units are tested according the requirements in the Engineering Recommendation G59/3. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the Engineering Recommendation G59/3.

Appendix 13.1 Type Testing a Generating Unit

Extract from test report according the Engineering Recommendation G59/3

Nr. PVUK140529C19

Protection. Voltage tests.						
230V grid-setting						
Function	Setting		Trip test		No trip test	
	Voltage	Time delay	Voltage	Time delay	Voltage / time	Confirm no trip
U/V stage 1	200,1V	2,5s	199,4V	2,640s	204,1V / 3,5s	No trip
U/V stage 2	184V	0,5s	183,3V	0,636s	188V / 2,48s	No trip
					180V / 0,48s	No trip
O/V stage 1	262,2V	1,0s	262,3V	1,111s	258,2V 2,0s	No trip
O/V stage 2	273,7V	0,5s	273,6V	0,638s	269,7V 0,98s	No trip
					277,7V 0,48s	No trip

Protection. Voltage tests.						
240V grid-setting						
Function	Setting		Trip test		No trip test	
	Voltage	Time delay	Voltage	Time delay	Voltage / time	Confirm no trip
U/V stage 1	208,8V	2,5s	208,9V	2,536s	212,9V / 3,5s	No trip
U/V stage 2	192V	0,5s	192,1V	0,541s	196,2V / 2,48s	No trip
					187,8V / 0,48s	No trip
O/V stage 1	273,6V	1,0s	273,5V	1,044s	269,4V 2,0s	No trip
O/V stage 2	285,6V	0,5s	285,5V	0,533s	281,4V 0,98s	No trip
					289,8V 0,48s	No trip

Note. For Voltage tests the Voltage required to trip is the setting $\pm 3,45V$. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting $\pm 4V$ and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

Appendix 13.1 Type Testing a Generating Unit

Extract from test report according the Engineering Recommendation G59/3

Nr. PVUK140529C19

Protection. Frequency tests.						
Function	Setting		Trip test		No trip test	
	Frequency	Time delay	Frequency	Time delay	Frequency / time	Confirm no trip
U/F stage 1	47,5Hz	20s	47,5Hz	20,26s	47,7Hz / 25s	No trip
U/F stage 2	47Hz	0,5s	47Hz	0,737s	47,2Hz / 19,98s	No trip
					46,8Hz / 0,48s	No trip
O/F stage 1	51,5Hz	90s	51,5Hz	90,293s	51,3Hz / 95s	No trip
O/F stage 2	52Hz	0,5s	52Hz	0,656s	51,8Hz / 89,98s	No trip
					52,2Hz / 0,48s	No trip

Note. For Frequency Trip tests the Frequency required to trip is the setting $\pm 0,1$ Hz. In order to measure the time delay a larger deviation than the minimum required to operate the projection can be used. The "No-trip tests" need to be carried out at the setting $\pm 0,2$ Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

Protection. Loss of Mains.						
BS EN 62116						
Balancing load on islanded network	33% of -5% Q Test 22	66% of -5% Q Test 12	100% of -5% P Test 5	33% of +5% Q Test 31	66% of +5% Q Test 21	100% of +5% P Test 10
Trip time. Ph1 fuse removed	74ms	83ms	83ms	62ms	114ms	72ms

Note for technologies which have a substantial shut down time this can be added to the 0,5 seconds in establishing that the trip occurred in less than 0,5s. Maximum shut down time could therefore be up to 1,0 seconds for these technologies.

Indicate additional shut down time included in above results. (Integrated interface switch)	Type of switching equipment 1: Relay with 15ms Type of switching equipment 2: Relay with 15ms
--	--

Appendix 13.1 Type Testing a Generating Unit

Extract from test report according the Engineering Recommendation G59/3

Nr. PVUK140529C19

Protection. Re-connection timer.				
Test should prove that the reconnection sequence starts in no less than 20 seconds for restoration of voltage and frequency to within the stage 1 settings of table 10.5.7.1.				
Voltage				
Time delay setting		Measured delay		
20s		47s		
Frequency				
Time delay setting		Measured delay		
20s		44s		
230V grid-setting				
	Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 1.			
	At 266,2V	At 196,1V	At 47,4Hz	At 51,6Hz
Confirmation that the Generating Unit does not re-connect.	No reconnection	No reconnection	No reconnection	No reconnection
240V grid-setting				
	Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 1.			
	At 277,8V	At 204,5V	At 47,4Hz	At 51,6Hz
Confirmation that the Generating Unit does not re-connect.	No reconnection	No reconnection	No reconnection	No reconnection

Protection. Frequency change, Stability test.				
	Start Frequency	Change	End Frequency	Confirm no trip
Positive Vector Shift	49,5Hz	+9 degrees		No Trip
Negative Vector Shift	50,5Hz	- 9 degrees		No Trip
Positive Frequency drift	49,5Hz	+0,19Hz/sec	51,5Hz	No Trip
Negative Frequency drift	50,5Hz	-0,19Hz/sec	47,5Hz	No Trip

Appendix 13.1 Type Testing a Generating Unit

Extract from test report according the Engineering Recommendation G59/3

Nr. PVUK140529C19

Power Quality. Harmonics.						
Generating Unit tested to BS EN 61000-3-12						
Generating Unit rating per phase (rpp)						
	At 45-55% of rated ouput 2,512kW		100% of rated output 5,015kW			
Harmonic	Measured Value (MV) in Amps	Measured Value (MV) in %	Measured Value (MV) in Amps	Measured Value (MV) in %	Limit in BS EN61000-3-12 in %	
					1 phase	3 phase
2nd	0,105	0,49	0,198	0,91	8%	8%
3rd	0,103	0,47	0,153	0,70	21,6%	N/A
4th	0,033	0,15	0,062	0,28	4%	4%
5th	0,082	0,38	0,115	0,53	10,7%	10,7%
6th	0,019	0,09	0,038	0,17	2,67%	2,67%
7th	0,050	0,23	0,068	0,31	7,2%	7,2%
8th	0,015	0,07	0,029	0,13	2%	2%
9th	0,049	0,22	0,065	0,30	3,8%	N/A
10th	0,011	0,05	0,024	0,11	1,6%	1,6%
11th	0,034	0,16	0,048	0,22	3,1%	3,1%
12th	0,010	0,04	0,021	0,10	1,33%	1,33%
13th	0,041	0,19	0,053	0,25	2%	2%
14th	0,009	0,04	0,018	0,08	N/A	N/A
15th	0,031	0,14	0,043	0,20	N/A	N/A
16th	0,009	0,04	0,016	0,07	N/A	N/A
17th	0,034	0,16	0,049	0,23	N/A	N/A
18th	0,010	0,04	0,015	0,07	N/A	N/A
19th	0,030	0,14	0,044	0,20	N/A	N/A
20th	0,010	0,05	0,014	0,07	N/A	N/A
21th	0,029	0,13	0,046	0,21	N/A	N/A
22th	0,011	0,05	0,014	0,06	N/A	N/A
23th	0,028	0,13	0,043	0,20	N/A	N/A
24th	0,012	0,05	0,014	0,07	N/A	N/A
25th	0,025	0,11	0,044	0,20	N/A	N/A
26th	0,012	0,06	0,015	0,07	N/A	N/A
27th	0,024	0,11	0,044	0,20	N/A	N/A
28th	0,013	0,06	0,016	0,07	N/A	N/A
29th	0,023	0,10	0,044	0,20	N/A	N/A
30th	0,019	0,09	0,017	0,08	N/A	N/A
31th	0,020	0,09	0,043	0,20	N/A	N/A
32th	0,011	0,05	0,017	0,08	N/A	N/A
33th	0,016	0,07	0,039	0,18	N/A	N/A
34th	0,009	0,04	0,016	0,07	N/A	N/A
35th	0,016	0,07	0,037	0,17	N/A	N/A
36th	0,008	0,04	0,014	0,07	N/A	N/A
37th	0,013	0,06	0,031	0,14	N/A	N/A
38th	0,007	0,03	0,013	0,06	N/A	N/A
39th	0,015	0,07	0,029	0,13	N/A	N/A
40th	0,006	0,03	0,011	0,05	N/A	N/A
THD ₄₀	1,01%		1,63%		23%	13%
PWHD	2,16%		3,73%		23%	22%

Appendix 13.1 Type Testing a Generating Unit

Extract from test report according the Engineering Recommendation G59/3

Nr. PVUK140529C19

Power Quality. Power factor.				
230V grid-setting				
	216,2V	230V	253V	Measured at three voltage levels and at full output. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test.
Measured value	0,9990	0,9991	0,9992	
Limit	>0,95	>0,95	>0,95	
240V grid-setting				
	225,6V	240V	264V	Measured at three voltage levels and at full output. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test.
Measured value	0,9978	0,9985	0,9991	
Limit	>0,95	>0,95	>0,95	

Power Quality. Voltage fluctuation and Flicker.								
	Starting			Stopping			Running	
	dmax	dc	d(t)	dmax	dc	d(t)	Pst	Plt 2 hours
Measured values at test impedance	0,011%	0,250%	0,810%	0,011%	0,250%	0,810%	0,322	0,22
Normalised to standard impedance	0,011%	0,250%	0,810%	0,011%	0,250%	0,810%	0,322	0,22
Limits set under BS EN 61000-3-11	4%	3,3%	3,3% 500ms	4%	3,3%	3,3% 500ms	1,0	0,65
Test impedance	R	0,24* 0,4^		Ω		XI	0,15* 0,25	Ω
Standard impedance	R	0,24* 0,4^		Ω		XI	0,15* 0,25^	Ω

Power Quality. DC injection.			
Test level power	10%	55%	100%
Recorded value	7mA	8mA	20mA
As % of rated AC current	0,032%	0,037%	0,092%
Limit	0,25%	0,25%	0,25%

Appendix 13.1 Type Testing a Generating Unit

Extract from test report according the Engineering Recommendation G59/3

Nr. PVUK140529C19

Fault level Contribution.					
For a directly coupled SSEG			For a Inverter SSEG		
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	I_p	N/A	20ms	57	0
Initial Value of aperiodic current	A	N/A	100ms	57	0
Initial symmetrical short-circuit current*	I_k	N/A	250ms	57	0
Decaying (aperiodic) component of short circuit current*	i_{DC}	N/A	500ms	57	0
Reactance/Resistance Ratio of source*	X/R	N/A	Time to trip	0,0014	In seconds

For rotating machines and linear piston machines the test should produce a 0s – 2s plot of the short circuit current as seen at the Generating Unit terminals.

* Values for these parameters should be provided where the short circuit duration is sufficiently long to enable interpolation of the plot.

Self Monitoring – Solid state switching.	N/A
It has been verified that in the event of the solid state switching device failing to disconnect the Generating Unit, the voltage on the output side of the switching device is reduced to a value below 50 volts within 0,5 seconds.	
Note. Unit do not provide solid state switching relays. In case the semiconductor bridge is switched off, then the voltage on the output drops to 0. In this case the relays on the output will also open.	