



Certificate of Compliance

CERTIFICATE

Applicant: **Delta Electronics, Inc.**
39 Section 2, Huandong Road, Shanhua District,
Tainan City 74144,
Taiwan, R.O.C.

Product: **Photovoltaic Inverter with integrated automatic disconnection device between a generator and the public low-voltage grid**

Model:	M100A_280	
Output Voltage:	400Vac, 3Ph+PE, 50/60Hz	480Vac, 3Ph+PE, 50/60Hz

Intended use:
Automatic disconnection device with three-phase mains surveillance in accordance with VDE 0126-1-1 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:
SOP-9-1_15 GCC Certification Program, 09/21
Based on:
DIN VDE 0126-1-1 (VDE V 0126-1-1):2013-08
Automatic disconnection device between a generator and the public low-voltage grid

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 23PP353-07_0

Certificate No: 23-429-00

Date of issue: 2023-11-08



Kiwa Primara GmbH
Gewerbestraße 28
87600 Kaufbeuren
Germany
Tel. +49 8341 99726-0
primara@kiwa.com
www.kiwa.de



Tanja Rottach
Certification Engineer